

SECTION 20 10 13

COMMON MATERIALS AND METHODS FOR FACILITY SERVICES – FIRE SUPPRESSION, PLUMBING AND HVAC

PART 1 - GENERAL

1.01 SECTION INCLUDES

- A. Standard pipe and fittings
- B. Gas piping
- C. Diesel exhaust pipe
- D. Hydronic piping for elevators
- E. Hydronic piping
- F. Branch outlets
- G. Pipe joint materials
- H. Gaskets
- I. Insulating connections
- J. Expansion joints
- K. Y-type strainers
- L. Gages and test plugs
- M. Thermometers
- N. Access doors and panels
- O. Pipe sleeves
- P. Casings
- Q. Valves

1.02 RELATED SECTIONS

- A. Site work and site facilities for water distribution system, sanitary sewerage system, and site drainage system are specified in applicable sections.

1.03 MEASUREMENT AND PAYMENT

- A. Separate measurement or payment will not be made for the Work required under this section. All costs in connection with the Work Specified here in will be considered to be included or incidental to the Work of this contract.

1.04 REFERENCES

- A. American National Standards Institute (ANSI):

1. ANSI B1.20.1 Pipe Threads, General Purpose (Inch)
2. ANSI B16.1 Cast Iron Pipe Flanges and Flanged Fittings
3. ANSI B16.3 Malleable Iron Threaded Fittings
4. ANSI B16.5 Pipe Flanges and Flanged Fittings
5. ANSI B16.9 Factory-Made Wrought Steel Buttwelding Fittings
6. ANSI B16.11 Forged Fittings, Socket-Welding and Threaded
7. ANSI B16.12 Cast Iron Threaded Drainage Fittings
8. ANSI B16.18 Cast Copper Alloy Solder Joint Pressure Fittings
9. ANSI B16.22 Wrought Copper and Copper Alloy Solder Joint Pressure Fittings
10. ANSI B36.10 Welded and Seamless Wrought Steel Pipe

- B. American Society of Mechanical Engineers (ASME):

1. ASME Boiler and Pressure Vessel Code, Section VIII and Section IX

- C. American Society for Testing and Materials (ASTM):

1. ASTM A47 Specification for Ferritic Malleable Iron Castings
2. ASTM A53 Specification for Pipe, Steel, Black and Hot-Dipped Zinc Coated, Welded and Seamless
3. ASTM A74 Specification for Cast Iron Soil Pipe and Fittings
4. ASTM A105/A105M Specification for Carbon Steel Forgings for Piping Applications
5. ASTM A135 Specification for Electric-Resistance-Welded Steel Pipe
6. ASTM A139 Specification for Electric-Fusion (Arc)-Welded Steel Pipe (NPS 4 and Over)

7.	ASTM A153/	Specification for Zinc Coating (Hot-Dip) on Iron and Steel A153M	Hardware
8.	ASTM A181/ A181M	Specification for Carbon Steel Forgings for General-Purpose Piping	
9.	ASTM A183	Specification for Carbon Steel Track Bolts and Nuts	
10.	ASTM A194/ A194M	Specification for Carbon and Alloy Steel Nuts for Bolts for High-Pressure and High-Temperature Service	
11.	ASTM A197	Specification for Cupola Malleable Iron	
12.	ASTM A234/ A234M	Specification for Piping Fittings of Wrought Carbon Steel and Alloy Steel for Moderate and Elevated Temperatures	
13.	ASTM A395	Specification for Ferritic Ductile Iron Pressure-Retaining Castings for Use at Elevated Temperatures	
14.	ASTM A536	Specification for Ductile Iron Castings	
15.	ASTM A582/ A582M	Specification for Free-Machining Stainless Steel Bars	
16.	ASTM A795	Specification for Black and Hot-Dipped Zinc-Coated (Galvanized) Welded and Seamless Steel Pipe for Fire Protection Use	
17.	ASTM B32	Specification for Solder Metal	
18.	ASTM B62	Specification for Composition Bronze or Ounce Metal Castings	
19.	ASTM B88	Specification for Seamless Copper Water Tube	
20.	ASTM B124	Specification for Copper and Copper Alloy Forging Rod, Bar, and Shapes	
21.	ASTM B306	Specification for Copper Drainage Tube (DWV)	
22.	ASTM C14	Concrete Sewer, Storm Drain and Culvert Pipe	
23.	ASTM C564	Rubber Gasket for Cast Iron Soil Pipe and Fittings	
24.	ASTM C700	Vitrified Clay pipe, Extra Strength	
25.	ASTM D256	Test Methods for Determining the Pendulum Impact Resistance of Notched Specimens of Plastics	
26.	ASTM D570	Test Method for Water Absorption of Plastics	
27.	ASTM D638	Test Method for Tensile Properties of Plastics	
28.	ASTM D695	Test Method for Compressive Properties of Rigid Plastics	

29. ASTM D1784 Specification for Rigid Poly (Vinyl Chloride) (PVC) Compounds and Chlorinated Poly (Vinyl Chloride) (CPVC) Compounds
30. ASTM D1785 Specification for Poly (Vinyl Chloride) (PVC) Plastic Pipe, Schedules 40, 80, and 120
31. ASTM D2122 Test Method for Determining Dimensions of Thermoplastic Pipe and Fittings
32. ASTM D2235 Solvent cement for acrylonitrile plastic pipe and fitting
33. ASTM D2466 Specification for Poly (Vinyl Chloride) (PVC) Plastic Pipe Fittings, Schedule 40
34. ASTM D2467 Specification for Socket-Type Poly (Vinyl Chloride) (PVC) Plastic Pipe Fittings, Schedule 80
35. ASTM D2564 Specification for Solvent Cements for Poly (Vinyl Chloride) (PVC) Plastic Piping Systems
36. ASTM D2665 Poly (Vinyl Chloride) (PVC) Plastic Drain, Waste and Vent Pipe and Fittings
37. ASTM D2729 Poly (Vinyl Chloride) (PVC) Sewer Pipe and Fittings
38. ASTM D3139 Specification for Joints for Plastic Pressure Pipes Using Flexible Elastomeric Seals
39. ASTM F477 Specification for Elastomeric Seals (Gaskets) for Joining Plastic Pipe

D. American Welding Society (AWS):

1. AWS A5.1 Specification for Carbon Steel Electrodes for Shielded Metal Arc Welding
2. AWS A5.2 Specification for Carbon and Low Alloy Steel Rods for Oxyfuel Gas Welding
3. AWS A5.8 Specification for Filler Metals for Brazing and Braze Welding
4. AWS A5.29 Specification for Low Alloy Steel Electrodes for Flux Cored Arc Welding
5. AWS B2.1 Standard for Welding Procedure and Performance Qualification

E. American Water Works Association (AWWA):

1. AWWA C104 Cement-Mortar Lining for Ductile-Iron Pipe and Fitting for Water
2. AWWA C105 Polyethylene Encasement for Ductile-Iron Pipe Systems

3. AWWA C110 Ductile-Iron and Gray-Iron Fittings, 3 in. Through 48 in. (75 mm Through 1200 mm), for Water and Other Liquids
4. AWWA C606 Grooved and Shouldered Type Joints
5. AWWA C900 Polyvinyl Chloride (PVC) Pressure Pipe, 4 in. Through 12 in., for Water Distribution

F. Cast Iron Soil Pipe Institute (CISPI):

1. CISPI 301 Specification for Hubless Cast Iron Soil Pipe and Fittings for Sanitary and Storm Drains, Waste and Vent Pipe Applications

G. Federal Specifications (FS):

1. FS GG-G-76 Gages, Pressure and Vacuum, Dial Indicating (for Air Stream, Oil, Water, Ammonia, Chlorofluorohydrocarbon Gases and Compressed Gases)
2. FS WW-P-521 Pipe Fittings, Flange Fittings, and Flanges: Steel and Malleable Iron (Threaded and Butt Welding), Class 150
3. FS WW-U-501 Pipe Fitting, Cast Iron, Screwed, 125 and 250 Pound
4. FS WW-U-531 Unions, Pipe, Steel or Malleable Iron, Threaded Connection, 150 pound, 250 pound and 300 pound WSP
5. FS WW-V-1967 Valve, Butterfly (Threaded Ends and Solder Ends), Brass or Bronze

H. Department of Defense, Military Specifications (MIL):

1. MIL-G-13210 Gaskets, Rubber
2. MIL-S-16293 Strainers, Sediment, Pipe Line, Water, Air, Gas, Oil
3. MIL-V-13612 Valves, Relief, Pressure and temperature

I. Manufacturers Standardization Society (MSS):

1. MSS SP-70 Cast Iron Gate Valves, Flanged and Threaded Ends
2. MSS SP-80 Bronze Gate, Globe, Angle and Check Valves

J. National Association of Corrosion Engineers (NACE):

1. NACE RP0274 High-Voltage Electrical Inspection of Pipeline Coatings Prior to Installation

K. UL Underwriters Laboratories Inc.

1.05 DESCRIPTION

- A. The Contract Drawings show piping, ductwork, and facilities diagrammatically and do not show offsets, fittings, and accessories that may be required because of obstructing structural features and architectural finishes, interfering pipelines, ducts, and electrical conduits and devices. The Contractor shall be responsible for investigating carefully all such conditions for determining the implementation of routing pipelines and ductwork around such obstructions and interferences. The Contractor shall provide all such additional fittings, appurtenances, and accessories as required for routing pipelines and ductwork around obstructions and interferences and for providing complete and operable plumbing, mechanical, and fire protection installations.

1.06 REGULATORY REQUIREMENTS

- A. In addition to the foregoing referenced standards, the regulatory requirements that govern the work of these Specifications include the following codes and regulations, at a minimum:

1. California Code of Regulations:
 - a. Title 8, Subchapter 4, Construction Safety Orders
 - b. Title 19, Public Safety, State Fire Marshal
 - c. Title 24, Part 2, California Building Code
 - d. Title 24, Part 4, California Mechanical Code
 - e. Title 24, Part 5, California Plumbing Code
 - f. Title 24, Part 6, California Energy Code
 - g. Title 24, Part 9, California Fire Code
 - 1) UBC: Building Uniform Code
 - 2) UMC: Mechanical Uniform Code
 - 3) UPC: Plumbing Uniform Code
2. General Orders and Regulations of the State of California, Public Utilities Commission

1.07 SUBMITTALS

- A. General: Refer to Section 01 33 00 - Submittal Procedures, and Section 01 33 23 - Shop Drawings, Product Data, and Samples, for submittal requirements and procedures.

- B. List of Materials: Within 35 days after effective date of Notice to Proceed, submit a complete list of materials and equipment proposed for use together with applicable standards. Give name of manufacturer, brand name, and catalog number for each item. Submit the list complete at one time, with items arranged and identified in numerical sequence by Specification Section and Article number.
- C. Compliance with Applicable Codes and Standards:
1. Where equipment or materials are specified to conform to the standards of organizations such as ANSI, ASHRAE, ASME, and ASTM, submit evidence of such conformance for review and record purposes.
 2. The label or listing of the specified agency will be acceptable evidence.
 3. Instead of the label or listing, the Contractor may submit a written certificate from an approved, nationally recognized testing organization, adequately equipped and competent to perform such services, stating that the items have been tested and that the units conform to the specified standard.
 4. Where equipment or work is specified to conform to the ASME Boiler and Pressure Vessel Code, Section VIII, submit evidence that the equipment, fabrication, and installation of the work conform to the code as required.
 5. Submit evidence of compliance with seismic safety requirements in accordance with Title 24 of the California Code of Regulations.
 6. Submit evidence that welding methods and procedures comply with all requirements of AWS D10-9, Level AR-3, for joining of piping.
 7. Submit evidence of compliance with energy conservation standards of the California Code of Regulations, Title 24, Part 2, California Building Code, and Title 24, Part 6, California Energy Code.
- D. Factory Test and Inspection Certification:
1. Except as otherwise specified herein, where factory tests and inspections for materials and equipment specified in referenced documents are waived, provide certified copies of reports for tests performed on previously manufactured identical materials or equipment within the previous 12 months.
 2. Accompany test reports by signed statements from the manufacturer certifying that the previously tested material or equipment is physically, mechanically, and electrically identical to that proposed for this work. Include wiring and control diagrams.
- E. Shop Drawings: Show complete details for installation of the following listed items of equipment, assemblies, and appurtenances, including equipment to be furnished by the District:
1. Equipment installation details complete with vibration isolators and seismic bracing.
 2. Foundations for equipment anchorage and mounting.

3. Information and templates for installing bolts and studs in foundations.
 4. Anchorage and mounting methods, including isolation pads, showing adjustment and alignment.
 5. Pipe anchors, supports, and guides.
 6. Details of installation of temporary materials and equipment to be used in the work.
 7. Layout and complete details for piping and ductwork. Where Contract Drawings are diagrammatic, provide complete details for routing piping and ductwork at obstructions and interferences.
 8. Plan for performing the work, including the sequence of operations. Verify by field measurements and show the exact locations of existing utilities.
 9. Factory certified performance curves showing capacity and horsepower requirements.
 10. Wiring and control diagrams and logic diagrams when solid-state controllers are provided.
- F. Installer's Qualification: Certification of qualification of workers installing mechanical equipment, as required by Article 1.08.B herein.
- G. Operation and Maintenance Manuals: Submit operation and maintenance instructions and data for all equipment provided in accordance with the requirements of Section 01 78 23 - Operation and Maintenance Data. Include recommended maintenance materials and spare parts list for all installed equipment.

1.08 QUALITY ASSURANCE

- A. Installation Standards: Perform installation and testing of plumbing, mechanical, and fire protection work in accordance with the installation instructions and recommendations of the equipment and materials suppliers and welding material and procedures that conform to ASME code. Comply with all applicable codes and standards listed herein under Reference Standards and Regulatory Requirements.
- B. Installer's Qualifications: Installers shall be qualified in accordance with the following requirements:
1. Welders: Section IX of ASME Boiler and Pressure Vessel Code.
 2. Plumbers and Pipe Fitters: Under the direct responsible supervision of a plumber licensed by the State of California and subject to inspection by the Engineer.
- C. Inspection, Certification, and Testing of Coatings:
1. Furnish a manufacturer's certificate of compliance for all coating materials. Include in the certificate: material identification, quantity, batch number, date of manufacture, and other

laboratory data covering requirements of specifications under which the material is furnished.

2. Surface preparation, cleanliness, application, and adhesion shall conform with the coating manufacturers' specifications and will be subject to inspection by the Engineer.
3. Inspection of the pipe coating shall be conducted by a NACE qualified coatings inspector or personnel with equivalent training and experience. Conduct a visual inspection to locate holidays, disbandment, and improper application. Before installation, conduct a high voltage electrical inspection of the coating in accordance with NACE RP0274.

1.09 INTERFACE AND COORDINATION

- A. Interface and coordinate the work of this Section as required to provide complete and operable plumbing, mechanical, and fire protection systems.
- B. Interface and coordinate also with the Sections under Division 26 - Electrical, that require electrical equipment and services as part of the mechanical installation.
- C. Interface and coordinate the plumbing, mechanical, and fire protection work with the affected utility companies and utility districts, as applicable.
- D. Coordinate all openings for mechanical equipment in floors, walls, ceilings, and roofs, based on actual dimensions of purchased equipment.

1.10 STORAGE AND PROTECTION

- A. Storage: Store all materials and equipment in dry, ventilated, weather tight enclosures.
- B. Protecting Machined Surfaces: Apply a rust preventive on machined surfaces such as flanges and shafts. Use material of a type that is easily removable with solvent during equipment installation.
- C. Protecting Openings: Close pipe connections, ends, and other openings with easily removable plugs, stoppers, or flange covers.

1.11 SITE CONDITIONS:

- A. Visit the site of the work and thoroughly check details of work and working conditions, verify dimensions in the field, and advise the Engineer of discrepancies before ordering material and equipment or performing work. The Contractor shall be responsible for the coordination and proper relationship of the work to the structure and to the work of other trades.

PART 2 - PRODUCTS

2.01 CLASSES OF STANDARD PIPE AND FITTINGS

- A. Class Requirements: Service applications for the following classes of pipe and fittings are specified in other sections of these Specifications, or are indicated on the Contract Drawings. Where more than one class is indicated in the same run, either class may be used, but do not intermingle the classes.

B. Class B:

1. Pipe and Fittings: CISPI 301, service weight, plain end hubless cast iron soil pipe and fittings.
2. Joints: CISPI 301, no-hub coupling consisting of neoprene gaskets with stainless steel clamps and bolts.

C. Class C:

1. Pipe: ASTM A53 or ASTM A135, galvanized, Schedule 40 threaded pipes.
2. Fittings: ANSI B16.12, ASTM A74, ASTM D2466, and cast iron recessed drainage type threaded fittings.
3. Joints: Threaded and coupled joints, ANSI B1.20.1.

D. Class E:

1. Pipe: ASTM B88, Type K, hard copper tubing.
2. Fittings: ANSI B16.18 cast bronze solder fittings, or ANSI B16.22 wrought copper solder fittings and couplings.
3. Joints: Silver-brazed.

E. Class F:

1. Pipe: ASTM B88, Type L hard copper tubing.
2. Fittings: ANSI B16.18 cast copper or bronze solder fittings, or ANSI B16.22 wrought copper or bronze solder fittings and couplings.
3. Unions: ½ inch to 2 inches in size, provide cast brass, Class 150, with ground joint, brass to brass seat, and solder ends.
4. Joints: Silver brazed.

F. Class G:

1. Pipe: ASTM B306, Type DWV, copper drainage tubing, of sizes indicated.
2. Fittings: ANSI B16.18 cast copper or bronze solder fittings, or ANSI B16.22 wrought copper or bronze solder fittings and couplings.
3. Unions: Cast copper, brass, or bronze with ground joints and solder ends.
4. Joints: Silver brazed or solder of alloy required for installation conditions.

G. Class H:

1. Pipe: Polyvinyl chloride ASTM D1784 (PVC), ASTM D1785, Schedule 80, Type I, Grade 1.
2. Fittings: ASTM D2466 or ASTM D2467, socket weld, same material and schedule as pipe.
3. Joints: ASTM D2564 and ASTM D2855, socket welded with PVC solvent cement.

H. Class J:

1. Pipe: Pre-insulated piping used for buried insulated refrigeration piping. This shall consist of Type K copper tubing, surrounded by polyurethane foam insulation one inch thick, having a K factor of 0.13 Btu in/hr/ft², all surrounded by a jacket of ASTM D1784 PVC of 110 mils thickness.
2. Fittings: Same as for Class E pipe, with insulation and ASTM D1784 PVC jacket to match pipe as specified above.
3. Joints: Silver-brazed.

I. Class K: 4 Inches and Larger Pipe:

1. Pipe: AWWA C900, Class 200, DR14, per ASTM D2241 polyvinyl chloride (PVC) pipe with bell and spigot ends and flexible ring joints, meeting requirements of ASTM D2241.
2. Fittings: ASTM D1784, Class 12454-A or Class 12454-B, polyvinyl chloride (PVC) fittings, AWWA C900, Class 200, DR14.
3. Joints: ASTM D3139 gasketed bell joints with ASTM F477 gaskets.

J. Class R:

1. Pipe:
 - a. ASTM A53, Type S, Grade B, or ASTM A135, or ASTM A795, Schedule 40, seamless or electric-resistance welded, hot-dipped galvanized steel pipe.
2. Fittings:
 - a. ANSI B16.3, Class 300, banded, ASTM A197, malleable iron, ASTM A153/A153M galvanized threaded fittings, for 2 inches and smaller pipe.
 - b. ANSI B16.5, galvanized forged steel ASTM A181/A181M, Grade E class 60 or 70, or ASTM A105/A105M screwed.
 - c. ANSI B16.5 Class 150 galvanized cast iron companion flanges.
 - d. ANSI 21.1, AWWA C110, galvanized cast ductile iron fittings with ANSI B16.1 Class 125 flanges.

- e. ASTM A536 galvanized ductile iron or ASTM A47, Grade 32510, or ASTM 197 galvanized malleable iron grooved end couplings rated for 450 psig working pressure. Track type bolts for couplings shall be ASTM A183 or ASTM A194/A194M. Sealing gaskets shall have internal sealing lips projecting diagonally inward so the internal pressure serves to increase tightness of the seal when installed. Gaskets shall be Victaulic Grade E Type EPDM, Gustin Bacon Type II Butyl, or equivalent synthetic rubber elastomeric material specifically suited for fire protection service. Pipe ends shall be prepared with cut grooves in accordance with coupling manufacturer's instructions and the grooves shall be painted with Engineer approved zinc rich primer. The term "cut " is defined as requiring shaving of the metal to form a groove; rolled grooves are unacceptable. Grooved end couplings, gaskets and fittings shall be from the same manufacturer.

3. Joints:

- a. 2 inches and Smaller: Threaded.
- b. Larger than 2 inches: Flanged or grooved end.

4. Unions and Couplings:

- a. 2 inches and smaller: ANSI B16.3, Class 300, banded, malleable iron, AAR pattern, threaded with brass or bronze seats.
- b. Larger than 2 inches: Flanged or grooved (end) couplings.

5. Flanges: Flange gaskets shall be full-face, MIL-G-13120, rubber, 1/16 inch thick.

K. Class S:

1. Pipe:

- a. 2-1/2 inches and Smaller Pipe: ASTM A53, Type S, Grade B, or ASTM A135, or ASTM A795, Schedule 40, seamless or electric-resistance welded, hot-dipped galvanized steel pipe.
- b. Pipe 3 inches and 4 inches: ASTM A135 or ASTM A795, ANSI B36.10, Schedule 10, electric-resistance welded, hot-dipped galvanized steel pipe.
- c. Pipe 6 inches and Larger: ASTM A135 or ASTM A795, ANSI B36.10, Schedule 10S, (minimum wall thickness 0.134 inch for 6-inch pipe, 0.188 inch for 8-inch and 10-inch pipe, 0.250 inch for 12-inch and larger pipe) electric-resistance welded, hot-dip galvanized steel pipe.

2. Fittings:

- a. ANSI B16.3, Class 300, banded, galvanized malleable iron, ASTM A197, malleable iron, ASTM A153/A153M galvanized threaded fittings, for 2 inches and smaller pipe.

- b. ANSI B16.5, galvanized forged steel ASTM A181/A181M, Grade E Class 60 or 70, or ASTM A105/A105M screwed, Class 150 companion flanges for schedule 40 pipe wall thickness only. For schedule 10S wall thickness, provide ASTM A536, galvanized ductile iron, ASTM A47, Grade 32510, or ASTM 197, galvanized malleable iron, rated for 450 PSI working pressure, grooved flanged couplings, ANSI B16.5 class 150 drilling, ANSI 21.1, AWWA C110, galvanized cast ductile iron fittings with ANSI B16.1, Class 125 flanges.
 - c. ASTM A536, galvanized ductile iron, ASTM A47, Grade 32510, or ASTM 197, galvanized malleable iron, rated for 450 PSI working pressure, grooved couplings. Provide ASTM A183 or ASTM A194/A194M track type bolts for couplings. Sealing gaskets shall have internal sealing lips projecting diagonally inward so that internal pressure serves to increase tightness of the seal when installed. Gaskets shall be Victaulic Grade E type EPDM, Gustin Bacon Type II Butyl, or equivalent synthetic-rubber elastomeric material. Pipe grooves shall be cut in accordance with coupling manufacturer's specification. Grooved and couplings, gaskets, and fittings shall be from the same manufacturer.
- 3. Joints:
 - a. 2 inches and smaller: Threaded.
 - b. Larger than 2 inches: Flanged or grooved, cut on Schedule 40. Pipe grooves shall be cut or rolled in accordance with coupling manufacturer's specifications. The term "cut" is defined as requiring shaving of metal to form a groove.
- 4. Unions and Couplings:
 - a. 2 inches and smaller: ANSI B16.3, Class 300, banded, malleable iron, AAR pattern, threaded with brass or bronze seats.
 - b. Larger than 2 inches: Flanged or grooved (end) couplings.
- 5. Flanges: Flange gaskets shall be full-face, MIL-G-13120, rubber, 1/16-inch thick.
- 6. Grooved Couplings:
 - a. Provide ASTM A536 galvanized ductile iron, ASTM A47, Grade 32510, or ASTM A197 galvanized malleable iron, grooved couplings rated for 450 psig working pressure. Provide ASTM A183 or ASTM A194/A194M track type bolts for couplings.
 - b. Sealing gaskets shall have internal sealing lips projecting diagonally inward so that internal pressure serves to increase tightness of the seal when installed. Gaskets shall be Victaulic Grade E type EPDM, Gustin Bacon Type II butyl, or equivalent synthetic-rubber elastomeric material.
 - c. Pipe grooves shall be cut in accordance with coupling manufacturer's specification. The term "cut" is defined as requiring shaving of metal to form a groove; rolled grooves are unacceptable. Groove end couplings, gaskets, and fittings shall be from the same manufacturer.

2.02 GAS PIPING:

A. Below Grade Piping: Underground natural gas piping shall be provided in accordance with the following requirements:

1. 3 inches and smaller Pipe: ASTM D1248, standard specification for polyethylene plastic molding and extrusion materials, Type II, Class B, Category 5, Grade P24 polyethylene IPS tubing having a PPI hydrostatic design stress rating (HDS) of 630 PSI at 73.4 degree Fahrenheit. Pipe shall be in accordance with ASTM D2513 and the standard dimensional ratio (SDR) shall be as follows: 7.0 for ½ inch, 11.0 for ¾ inch and 1 inch, 10 for 1-1/4 inch, 11.0 for 2 inch, and 11.5 for 3 inch.

Note: Straight lengths of 2 inch and 3 inch pipe may be substituted for coiled tubing provided the pipe meets the minimum requirements specified herein.

2. 4 inches and larger pipe: ASTM D1248 and ASTM D2513, polyethylene pipe having a PPI HDS of 630 psi at 73.4 degrees F, and having 11.5 SDR.
3. Fittings all sizes: ASTM D2513 and ASTM D2683, polyethylene socket weld, confirming to ASTM-2683.
4. Joints: Socket weld only.
5. Meter Risers: Schedule 40 black steel pipe, epoxy-coated, meeting requirements of ASTM D2513 and D.O.T. 192-283 CSA approved and IAMPO listed, transition riser with double “O” ring seal transition fitting for polyethylene piping connection.

B. Above Grade Piping: Black steel, schedule 80 pipe, with threaded, Class 300 malleable iron fittings and ground joint unions up 2-1/2 inches, and Class 150 flanged for 3 inches and larger pipe, meeting District and jurisdictional authority standards.

2.03 DIESEL EXHAUST PIPE:

A. Pipe: Factory-built double wall pipe. Outer jacket shall be aluminum coated steel 0.025 inches thick and inner pipe shall be Type 304 or Type 316 stainless steel 0.035 inches thick. Provide air gap of one-inch minimum between pipe and jacket. Pipe shall be laboratory tested, classified, and listed by a nationally recognized testing agency.

B. Fittings: Provide manufacturer's standard fittings and installation accessories for use with specified pipe. Provide special fittings as indicated.

C. Joints: Pipe joints shall be sealed by use of V-bands and high temperature joint cement as recommended by the pipe manufacturer.

2.04 HYDRONIC PIPING FOR ELEVATORS

A. Provide hydraulic line between Elevator Machine Room and Hoistway Pits, as indicated. If embedded, wrap lines as indicated.

1. Pipe: ASTM A53, Schedule 80, black steel. Pipe shall exhibit a 30-degree bevel angle at the welded ends.
 2. Fittings 2 inches and smaller: ASTM A105, Grade II, and ANSI B16.11, 200 pound forged steel socket weld fittings.
 3. Fittings 2-1/2 inches and larger: ASTM A234, and ANSI B16.9, standard weight, butt-welding fittings.
 4. Joints 2 inches and smaller: Threaded and coupled.
 5. Joints 2 ½ inches and larger: Butt-welded.
 6. Union 2 inches and smaller: ASTM A105, ANSI 16.11 – 200 pound socket weld with ground joints.
 7. Unions 2½ inches and larger: Flanged.
 8. Flanges: ANSI B16.5 and ASTM A181, Grade I, forged raised or insert face, 150-pound class, slip-on or weld neck to suit work site conditions.
- B. Provide ½ inch diameter hydraulic scavenger (oil return) line between Elevator Machine Rooms and Hoistway Pits, where indicated.
1. Pipe: ASTM A53, Schedule 40, black steel, screwed.
 2. Fittings: Threaded, black 2000 pound ASTM A105, Grade II, MSSSP 49 forged steel.

2.05 HYDRONIC PIPING

- A. Provide class E pipe, fittings, joints and joining materials as specified herein
- B. Automatic Air Vent: Designed to vent automatically with float principle; bronze body and nonferrous internal parts; 150 psig working pressure, 250 degree F operating temperature, with ¼ inch discharge connection and ½-inch inlet connection. Provide ½-inch ball valve at each air vent to permit service of air vent.
- C. Pump Suction Diffusers: Angle or straight pattern, pump inlet fitting, 175 psig pressure rating; cast iron body and end cap. Include bronze start-up and stainless steel permanent strainers; stainless steel straightening vanes; drain plug; and factory fabricated support
- D. Expansion Tank: Provide welded steel expansion tank, size and capacity as indicated. Tank shall be fitted with lifting rings, seismic anchorage and skirt as required. Fitting connections shall be same as for pipe. Provide sight glass. Paint tank with two coats of primer.
- E. Air Separator: Provide external air separation unit with integral system strainer as indicated. Strainer shall be removable, of stainless steel, with 3/16 inch diameter perforations, and shall have a free area of not less than five times the cross sectional area of the connecting pipe.

Provide seismic anchorage. Provide blow down connection. Paint separator with two coats of primer.

F. Valve Applications:

1. General-Duty Valve Applications: Unless otherwise indicated, use the following valve types:
 - a. Shutoff Duty: Gate, ball, and butterfly valves.
 - b. Throttling Duty: Globe, ball and butterfly valves.
2. Install shutoff-duty valves at each branch connection to supply mains, at supply connections to each piece of equipment, and elsewhere as indicated.
3. Install throttling-duty valves at each branch connection to return mains, at return connections to each piece of equipment, and elsewhere as indicated.
4. Install calibrated balancing valves on the outlet of each heating or cooling element, and elsewhere as required to facilitate system balancing.
5. Install drain valves at low points in mains, risers, branch lines, and elsewhere as required for system drainage.
6. Install check valves on each pump discharge and elsewhere as required to control flow direction, unless triple-duty valves are indicated.
7. Install safety relief valves on hot water boilers and elsewhere as required by ASME Boiler and Pressure Vessel Code. Pipe discharge to floor without valves. Comply with ASME BPVC Section VIII, Division 1, for installation requirements.

G. Piping Installation:

1. Install piping in accordance with Contract Specifications Section 20 10 13 - Common Materials and Methods for Facility Services – Fire Suppression, Plumbing and HVAC.
2. Locate groups of pipes parallel to each other, spaces to permit applying insulation and servicing of valves.
3. Install drains at low points in mains, risers, and branch lines consisting of a tea fitting, $\frac{3}{4}$ inch NPS ball valve, and short $\frac{3}{4}$ inch NPS threaded nipple and cap.
4. Install piping at a uniform grade of 0.2 percent upward in direction of flow.
5. Reduce pipe sizes using eccentric reducer fittings installed with level side up.

6. Install branch connections to mains using tee fittings in main with takeoff out from bottom of main line, except for up-feed risers with takeoff out from top of main line.
7. Install unions in pipes 2-inch NPS and smaller, adjacent to each valve, at final connections of each piece of equipment and elsewhere as indicated. Unions are not required at flanged connections.
8. Install flanges on valves, apparatus, and equipment having 2-1/2-inch NPS and larger connections.
9. Install flexible connectors at inlet and discharge connections to pumps (except inline pumps) and other vibration-producing equipment.
10. Install strainers on supply side of each control valve, pressure-reducing valve, pressure-regulating valve, solenoid valve, in-line pump, and elsewhere as indicated. Install 3/4-inch NPS nipple and ball valve in blow-down connection of strainers 2-inch NPS and larger.
11. Provide hangers, supports and sleeves in accordance with Contract Specifications Section 20 20 13 - Pipe Sleeves, Supports, and Anchors for Facility Services. Anchor piping to ensure proper direction of expansion and contraction.
12. Temperature and Pressure Control Weldolets: Furnish and install welded threadolets for temperature and pressure control. Separable wells and flow switches are specified in Contract Specifications Section 23 09 00 - Instrumentation and Control for HVAC. Coordinate sizes and locations with Contract Specifications Section 23 09 00 - Instrumentation and Control for HVAC.

H. Hydronic Specialties Installation:

1. Install automatic air vents at high points in system, heat-transfer coils, and elsewhere as required for system air venting.
2. Install dip-tube fittings in boiler outlet. Run piping to expansion tank with a 2 percent upward slope toward tank. Connect boiler-outlet piping.
3. Chemical Feeders: Provide valved connections for chemical feeders. Permanent chemical feeders will be furnished by others. Provide temporary equipment for injection of initial chemical charge.
4. Install expansion tanks as indicated. Vent and purge air from hydronic system, and charge tank with proper air charge to suit system design requirements.

I. Terminal Equipment Connections:

1. Install control valves in accessible locations close to equipment.

2. Install bypass piping with ball or butterfly valve around control valve. Where multiple, parallel control valves are installed, only one bypass is required.
3. Install pressure gage at coil inlet connections.

J. Testing:

1. Use ambient temperature water as testing medium.
2. Use vents installed at the high points of system to release trapped air while filling system. Use drains installed at low points for complete removal of liquid.
3. Examine system to ensure that equipment and parts that cannot withstand test pressures are properly isolated. Examine test equipment to ensure that it is tight and that low-pressure filling lines are disconnected.
4. Subject piping system to hydrostatic test pressure that is not less than 1.5 times the design pressure. Test pressure shall not exceed maximum pressure for any vessel, pump, valve, or other component in system under test. Check to verify that stress due to pressure at bottom of vertical runs does not exceed 90 percent of specified minimum yield strength or 1.7 times "SE" value in Appendix A of ASME B31.9.
5. After hydrostatic test pressure has been applied for at least 10 minutes, examine piping, joints, and connections for leakage. Eliminate leaks by tightening, repairing, or replacing components as appropriate, and repeat hydrostatic test until there are no leaks.
6. Prepare and submit written report of testing.

K. Adjusting and Cleaning:

1. After completing system installation, including outlet fittings and devices, inspect finish. Remove burrs, dirt, and construction debris, and repair damaged finishes including chips, scratches, and abrasions.
2. Fill the piping system with water and remove air. Flush each circulating system with an alkaline cleaning solution to remove grease and oil in the piping system. Solutions using trisodium phosphate shall be heated to temperatures of 160 degrees F to 180 degrees F. Other solutions may be submitted for approval. Drain and rinse with clean water.
3. Fill the piping system and remove air. Flush each circulating system with an acid cleaning solution to remove rust and scale. Use solutions in accordance with manufacturer's instructions. Drain and rinse with clean water.
4. Remove, clean, and replace strainer screens. After cleaning and flushing hydronic-piping system, but before balancing, remove disposable fine-mesh strainers in pump suction.

diffusers. Fill the piping system and remove air. Charge systems with initial chemical treatment as follows:

- a. Heating pH control, scale inhibitor, corrosion inhibitor, and conductivity controller.
5. Mark calibrated nameplates of pump discharge valves after hydronic system balancing has been completed, to permanently indicate final balanced position.

L. Commissioning:

1. Fill system and perform initial chemical treatment.
2. Check expansion tanks to determine that they are not air bound and that system is full of water.
3. Perform the following before operating the system:
 - a. Open valves to fully open position. Close coil bypass valves.
 - b. Check pump for proper direction of rotation.
 - c. Set automatic fill valves for required system pressure.
 - d. Check air vents at high points of systems, and determine that all are installed and operating freely (automatic type).
 - e. Set temperature controls so coils are calling for full flow.
 - f. Check operation of automatic bypass valves.
 - g. Check and set operating temperatures of boilers, chillers, and cooling towers to design requirements. Comply with requirements of Contract Specifications Section 23 05 93 - Testing, Adjusting, and Balancing for HVAC.
 - h. Lubricate motors and bearings.

2.06 BRANCH OUTLETS

- A. Refrigeration Piping: Wrought copper tees, Schedule 80, soldered.
- B. Welded Pipe: Tees or welding outlets, with branch size at least one size smaller than the main.
- C. Copper Tubing: Formed brazing outlets, with branch size at least two sizes smaller than the main or cast bronze tees.
- D. Threaded, socket-weld steel piping and PVC piping. Provide tees as specified under Article 2.01.

2.07 PIPE JOINT MATERIAL

- A. Silver Brazing Alloy: Comply with AWS A5.8 requirements, Class BA-g-1 for 1100 degrees F to 1500 degrees F melting temperature.
- B. Solder: ASTM B32, Grade 95 TA, up to 250 degrees F.
- C. Arc-Welding Electrodes: AWS A5.1 through AWS A5.29, as applicable.
- D. Welding Rods for Oxyacetylene Welding: AWS A5.2.

2.08 GASKETS

- A. For joints in soil, waste, vent, and drain piping, provide polychloroprene rubber cellular elastomeric preformed gasket and compatible sealing material as required for type of piping material used.

2.09 INSULATING CONNECTIONS

- A. For 2 inches and Smaller Piping: Provide insulating joints that consist of a 6-inch length of aluminum alloy pipe or approved equivalent with high-strength dielectric coating and dielectric unions or flanges at both ends. The unions shall be of two dissimilar metal parts; one end of same pipe material and mating end of aluminum with dielectric gasket.
- B. For 2-1/2 inches and Larger Piping: Provide dielectric insulating flanges constructed so that two pipes being connected are completely insulated from each other with no metal-to-metal contact. The flanges shall be galvanized and shall be made up with complete insulating components consisting of a dielectric gasket, bolt insulator sleeves, and bolt washers.

2.10 EXPANSION JOINTS

- A. Pressure Rating: 150-psig minimum at 250 degrees F.
- B. Type: Flanged, stainless steel, consisting of a corrugated bellows, capable of absorbing pipe movement in an axial or lateral direction. Provide with support rods to keep flange faces parallel during installation.
- C. Pipe-Alignment Guides: As recommended by the pipe joint manufacturer but not more than 5 feet on each side of each expansion joint, except in lines 4 inches or smaller, they may be not over 2 feet each side of the joint.
- D. Traverse Capacity of Joint: Not less than indicated.

2.11 Y-TYPE STRAINERS

- A. Strainer Requirements: Provide strainers full line size of connecting piping, 175 psig WOG pressure rating, with 304 series stainless steel 60 mesh screen, ASTM A126, Class B.
- B. 2 inches and Smaller: Brass or bronze body, threaded connections, screwed screen retainer, with centered blow down fitting and gate valve of the same size as blow off tapping.

- C. 2-1/2 inches and Larger: Cast-iron body, flanged connections, bolted screen retainer with off-center blow down fitting and gate valve of the same size as blow off tapping.

2.12 GAGES AND TEST PLUGS

- A. Test Plug: Provide test plugs conforming with FS GG-G-76, of sizes indicated, having 3 inch minimum diameter dial. Provide captive spring-loaded ball check in stainless steel housing with male thread for installation in threaded tee for locations indicated. At each site, provide a 1/4-inch female NPT adapter for that test gage.
- B. Gages: Operating range of gages shall be approximately 150 percent of indicated operating service pressure or 200 psig, whichever is greater. Draft gages for HVAC air filter shall be differential type calibrated 0-10 to 1 inch of water column.
 - 1. Calibration: Calibrated to two percent in middle one-third of dial range and equipped with means of front calibration.
 - 2. Movements: Phosphor-bronze bushed, rotary type.
 - 3. Panel Mounted: Flush mounting type in cast iron or aluminum cases.
 - 4. Stem or Pipe Mounted: Flangeless cases of drawn or stamped steel, or aluminum.
- C. Pressure-Differential Gages: Draft gages for HVAC air filter banks shall be pressure differential type with a calibrated range of 0.10 to 1 inch of water column.

2.13 THERMOMETERS

- A. Requirements: Provide thermometers with red reading mercury column and wide angle of visibility and high magnification of mercury column, of heavy, one-piece, extruded or cast brass or aluminum construction with glass front. Thermometer scales: maximum two degrees between graduations and 20 degrees between figures. Provide steel bulb chambers and brass separable sockets.
- B. Scale Lengths: 7 inches minimum for tanks and similar equipment, and 5 inches minimum for piping.
- C. Optional: Provide dial thermometer with 5 inch dials and liquid-filled thermal systems.

2.14 ACCESS DOORS AND PANELS

- A. Access Requirements: Provide manufactured or prefabricated wall and ceiling access panels for service access to equipment and valves. Comply with requirements of Section 08 31 00 - Access Doors and Panels. For access doors and panels in sheet metal ductwork and plenums, refer to Section 23 31 00 - HVAC Ducts and Casings, for requirements.

- B. Size: Large enough to permit removal of equipment, but not less than 12 inches by 12 inches net opening. Where entrance of service person is required, provide minimum opening of 24 inches by 24 inches.
- C. Construction: Refer to Section 08 31 00 - Access Doors and Panels, for requirements.

2.15 PIPE SLEEVES

- A. Pipe sleeves and seals shall comply with applicable requirements of Section 20 20 13 - Pipe Sleeves, Supports and Anchors for Facility Services.

2.16 CASINGS

- A. Casing Requirements: Provide minimum black steel pipe conforming to ASTM A53, Schedule 40, with polyethylene encasement in accordance with AWWA C105.
- B. Casing Insulators: High-density, injection-molded polyethylene casing insulator having the following properties:

1. Compressive strength (ASTM D695)..... 3200 psi
2. Tensile strength (ASTM D638, ASTM D651) 3100 - 5500 psi
3. Water absorption (ASTM D570) 0.1 percent
4. Impact strength (ASTM D256) 1.5 to 4.0 ft-lb/ in. of notch

- C. Casing End Seals:

1. Provide modular type mechanical casing seals consisting of interlocking synthetic rubber links shaped to fill the annular space between the pipe and casing and nonconductive pressure plates, with stainless steel compression bolts (T-head type) and nuts. Seals shall be sized in accordance with the manufacturer's requirements for the particular size of carrier pipe and casing involved to obtain a watertight seal and withstand indicated test pressure for casing.
2. Modular type mechanical seals for metallic carrier pipe inside a metallic casing shall be an insulating type designed to provide electrical isolation between the carrier pipe and casing.

2.17 VALVES

- A. Approved Valves: For wet standpipe and fire protection sprinkler systems, valves shall be listed and approved by nationally recognized agencies for intended service and shall bear stamp or label of the agency.
- B. Gate Valves:
 1. 2 inches and Smaller in Diameter: 150 pound, bronze, rising stem, wedge disc, union bonnet, threaded connection, conforming with requirements of MSS SP-80.
 2. 2-1/2 inches and Larger in Diameter: 125 pound, except 175 pounds for use on wet standpipe and fire protection sprinkler systems, iron body, rising stem, wedge disc,

OS&Y, flanged connection, provide chain wheel operators for valves 6 inches and larger mounted 8 feet above floor, conforming with requirements of MSS SP-70.

C. Globe Valves:

1. 2 inches and Smaller in diameter: 150 pound, bronze, rising stem, wedge disc, union bonnet, threaded connection, conforming with requirements of MSS SP-80.
2. 2-1/2 inches and Larger in Diameter: 125 pound, except 175 pounds for use on wet standpipe and fire protection sprinkler systems, iron body, rising stem, plug-type disc, OS&Y, flanged connection, provide chain wheel operators for valves 6 inches and larger mounted 8 feet above floor, conforming with requirements of MSS SP-85.

D. Swing Check Valve:

1. 2 inches and Smaller in Diameter: 150 pound, bronze threaded connection, with removable stainless steel hinge pin and screwed cap, suitable for operation in either horizontal or vertical position.
2. 2-1/2 inches and Larger in Diameter: 125 pound, flanged connection with removable stainless steel hinge pin and bolted cap.
3. Fire Protection Use: Spring-loaded swing check valve with grooved ends, cast-iron body, stainless-steel seat, hinge pin, spring and clapper, and elastomeric seal, suitable for horizontal or vertical installation, and 250 psig working pressure.

E. Butterfly Valves: Epoxy-coated body of ductile iron conforming to ASTM A395, equipped with ASTM A582/A582M, Type 420 stainless steel stem, EPDM encapsulated ASTM B124 brass disc, and EPDM "O" ring stem seals. The valve shall be assembled complete with a valve supervisory switch and a stem extension assembly. The stem extension shall have a hand crank and a reflectorized disc indicating valve disc position.

1. Where bronze valves are indicated or required, provide valves conforming to FS WW-V-1967.

F. Angle Hose Valves: Cast brass conforming to ASTM B62, rated for 300-psig non-shock service. Valves shall have fire department hose thread on discharge site, female NPT inlet, and shall be equipped with union bonnet, replaceable composition disc, and bronze stem. Hose valves shall be furnished with cast-bronze cap with chain attached to cap and valve, except the 1-1/2 inch angle hose valves installed in fire hose cabinets shall be connected to fire hose.

G. Air Release Valves: Cast-iron body with 300 series stainless-steel and bronze trim, combination air release and vacuum breaker type suitable for 300 psig working pressure.

H. Valve Supervisory Switch: Provide for post indicator valves, butterfly valves, and OS&Y gate valves for Fire Protection service only. Switches shall be mounted so as not to interfere with the normal operation of the valve and shall be adjusted to operate within two revolutions of the valve control or when the stem has moved no more than one-fifth of the distance from its normal position. The mechanism shall be internal in the gear operator of butterfly valve or contained in a weatherproof die cast metal housing that shall provide a 1/2-inch conduit entrance and incorporate the necessary facilities for attachment to the valve. The switch mechanism shall

have a minimum rated capacity of 10 amps at 125/250 volts AC and 2.5 amps at 24 volts DC. The entire installed assembly shall be tamper-resistant.

- I. Calibrated Plug Valves: 125 psig working pressure, 250 degree F maximum operating temperature, bronze body, plug valve with calibrated orifice. Provide with connections for portable differential pressure meter with integral check valves and seals. Valve shall have integral pointer and calibrated, scale to register degree of valve opening. Valves 2-inch and smaller shall have threaded connections; valves 2-1/2-inch and larger shall have flanged connections.
- J. Safety Relief Valves: Brass or bronze body with brass and rubber, wetted, internal working parts; to suit system pressure and heat capacity; according to ASME BPVC Section IV.
- K. Balancing Flow-Control Valves: Class 150, cast-iron housing, stainless- steel operating parts; threaded connections for 2-inch and smaller, flanged connections for 2-1/2-inch and larger. Factory set to automatically control flow rates within plus or minus 5 percent design, while compensating for system operating-pressure differential. Provide quick disconnect valves for flow measuring equipment. Provide metal identification tag with chain for each valve, factory marked with the zone identification valve model number and flow rate.
- L. Triple-Duty Valves: Angle or straight pattern; 175 psig pressure rating; cast iron body; pump discharge fitting. Include drain plug, bronze-fitted shutoff, balancing and check valve features.
- M. Pressure-Reducing Valves: MSS SP-80 valves 2 inches and smaller shall be all bronze construction meeting requirements of MSS SP-80. MSS-SP-85 valves 2-1/2 inches and larger shall be all cast iron construction meeting requirements of MSS SP-70. Valves 2-1/2 inches and smaller shall have threaded connections. Valves 3 inches and larger shall have flanged connections. Valves shall be stainless steel spring-loaded, single-seated, and suitable for tight shutoff under dead-end conditions. Provide with renewable stainless steel seat, nylon inserted diaphragm, and bolted spring chamber. Valves shall be rated for 300 psi working pressure, adjustable from 25 to 75 psi, factory set at 50 psi. Pressure gauges (or gauge ports) shall be installed upstream and down stream of the pressure-reducing valve.
- N. Safety Relief Valves:
 - 1. AGA Z21-22 and ASME BPVC Section IV, pressure and temperature relief valves shall be AGA design certified, ASME listed and rated, with bronze body, brass trim, stainless steel spring and silicone rubber seat disc. Pressure and temperature valves shall be installed on all water heaters and hot water storage tanks, rated for heating capacity of water heater.
 - 2. Valves shall be ASME rated for intended service, and shall be single-seated, bronze body and trim, stainless steel spring, adjusting screw with cap and threaded connections for 2-1/2 inches and smaller valves, and flanged connections for 3 inches and larger valves.

PART 3 - EXECUTION

3.01 INSTALLATION REQUIREMENTS

A. Protection of the Work:

1. Cover openings in ductwork, conduits, and piping, and temporarily seal openings to protect from contamination.
2. Protect materials and equipment from damage due to environmental conditions. Use protective cover, and protect from surface water by using raised platforms.
3. Protect unfinished work at the end of each workday from damage, contamination, and moisture by the use of plugs, caps, and covers, as applicable.
4. Protect piping and valves from damage pending performance of systems tests.
5. Protect installed thermometers and gauges from accidental damage by construction activity.
6. Following installation, and before final embedment, use temporary protective covers and fixtures to prevent damage from traffic and overburden loads that may damage or displace embedments.
7. Clean fixtures, piping, valves, finished brass, and equipment installed under this work. Drain and flush piping to remove grease and foreign matter. Flush air and gas piping with compressed dry nitrogen.

B. Locations of Fixtures and Equipment:

1. The mechanical sheets of the Contract Drawings are diagrammatical and not intended for use in determining the exact locations of the components of mechanical and electrical systems.
2. Refer to applicable sheets of the Contract Drawings to determine the exact locations of fixtures and equipment to be installed as well as the locations of items or equipment indicated to be installed by others.

3.02 INSTALLATION OF PIPING

- A. Install piping parallel to walls, floors, and ceilings, unless indicated otherwise. Clear obstructions, preserve headroom, and keep openings and passageways clear.
- B. Ream pipe and tube ends. Remove burrs.
- C. Remove scale and dirt, inside and outside, before assembly.
- D. Remove welding slag and foreign material from pipe and fitting materials.

- E. Should structural features or other work prevent running of pipes or setting of equipment at locations indicated, necessary minor deviations there from will be permitted, as approved by the Engineer.
- F. Run piping in chases or recesses in walls where provided, through openings in floors, and in furred ceilings; otherwise, as exposed pipes. Do not embed piping in or below the structure, except as indicated.
- G. Expanding or swaging of tubing to fit IPS fitting sockets will not be permitted.
- H. Provide reducing fittings where change in pipe size occurs. Reducing bushings shall not be used unless otherwise indicated.
- I. Provide couplings only where required pipe runs between fittings are longer than standard length of pipe being used. Reducing bushings shall not be used unless otherwise indicated. Make exposed polished or enameled piping connections to fixtures or equipment with special care to avoid damage to finished surfaces. Knurled pipe wrenches such as "Stilson Wrenches" shall not be used on chrome-plated brass pipe or polished stainless steel or aluminum tubing or equipment.
- J. Make changes in direction only with manufactured fittings.
- K. Provide expansion loops (bends) where indicated.
- L. Provide proper length bolts for each size flange on flanged connections. Bolts with excessive length of exposed threads will not be permitted. A minimum of three full threads is required to be exposed beyond the nut after tightening the assembly.
- M. Prevent entry of foreign matter during handling, assembling, and installation. Use compressed air, wire brush, solvent, and other acceptable means to remove scale, dirt, and other foreign matter from interior of piping before final connections are made. Protect open ends of pipe by capping, plugging, or by other acceptable methods.
- N. Anchor piping subject to expansion or contraction in a manner permitting such strains and stresses to be evenly distributed and alleviated by swing joints or expansion loops.
- O. Provide unions or flanges in piping connections to equipment.
- P. Install piping with sufficient pitch to ensure proper drainage and venting.
- Q. Make exposed polished or enameled piping connections to fixtures or equipment with special care to avoid damage to finished surfaces. Knurled pipe wrenches shall not be used on chrome-plated or polished stainless steel or aluminum tubing or equipment.
- R. Electrically isolate connections between piping of dissimilar metals, between District-owned and non-District-owned piping, where pressure piping enters any structure not more than 5 feet from point of entry inside the structure, and where indicated.
- S. Install class of piping as indicated. Plastic pipe will not be permitted under concrete structures and slabs and under any kind of pavement.

- T. Do not run water piping over electric switchboards, transformers, or electric motor starters.
- U. Provide changes in direction only with manufactured fitting.
- V. Provide proper length bolts for each size flange on flanged connections. Bolts with excessive length of exposed threads will not be permitted. A minimum of three full threads is required to be exposed beyond the nut after tightening the assembly.
- W. Prevent entry of foreign matter during handling, assembling, and installation. Use compressed air, wire brush, solvent, and other acceptable means to remove scale, dirt, and other foreign matter from interior of piping before final connections are made. Protect open ends of pipe by capping, plugging, or by other acceptable methods.
- X. Install piping with sufficient pitch to ensure proper drainage and venting.

3.03 INSTALLATION OF PIPE JOINTS AND CONNECTIONS

A. Installation Requirements:

1. Provide tool specifically designed for pipe cutting; debur all cut pipe ends. Make joints leak-tight. Test and remake leaky joints with new materials. Thread cement or calking shall not be used to remake leaky joints.
2. Do not use a sharp-toothed wrench in making up brass pipe or chrome-plated items.
3. Thread and length of threads shall be in accordance with applicable ANSI standards. Use a thread lubricant on male threads suitable for the proposed pipe service.
4. Soldered joints, ends of pipe, and insides of fittings shall be thoroughly cleaned and polished. Uniformly heat joint, and ensure capillary space is completely filled with solder, leaving a full bead of solder around the entire circumference of the joint.
5. Clean PVC pipe end with cleaning agent in accordance with manufacturer's recommendations.
6. All welded pipe joints, qualification of welders, and testing shall be performed in accordance with AWS B21.3.
7. Provide a gasket coated with the gasket manufacturer's recommended lubricant between the contact faces of the flanges.
8. Install hubless cast iron pipe, fittings, and joints in accordance with CISPI 301.

B. Copper Tubing Systems:

1. Use non-toxic silver-brazed joints for fuel oil and refrigerant piping. Flow nitrogen through tubing to prevent oxidation during brazing.
2. For other service, make joints with 95-5 tin-antimony (SN95, SN94, E) solder per ASTM B32.

3. Clean outside of tube and inside of fitting at point of contact with fine grit carborundum sandpaper to a bright finish without deposits before joining. Take care to prevent overheating of tube and fitting before joining. Before silver brazing, disassemble solder type valves used in refrigerant piping, and keep valve bodies cool by use of damp cloths or other approved methods.

C. Steel Pipe and Welding Fittings:

1. Make joints in welded piping by oxyacetylene or electric arc process with welding continuous around pipe. Use qualified welders and welding procedures as specified in AWS B2.1.
2. Hydraulic piping welding shall use gas tungsten arc weld (GTAW) to root pass, using AWS ER70S-2 or ER70S-6 filler metal with argon purge. Shield metal arc weld (SMAW) the remaining weld to completion with AWS E7018 low hydrogen electrodes. Metal gas welding will not be permitted on hydraulic lines.
3. Welded branch outlets on galvanized steel pipe shall be cleaned of weld splatter, and all surfaces in the vicinity thereof shall be wire brushed and coated with a zinc rich painting system having a 3 mil DFT as specified in Section 09 91 00 - Painting.

D. Polyvinyl Chloride (PVC) Pipe:

1. Threaded Joints: Make joints with Teflon pipe joint compound, or Teflon tape of type recommended by pipe and fitting manufacturer, suitable for service where it is to be used, conforming to ANSI B1.20.1.
2. Flanged Joints: When required, flanged joints may be used to connect to equipment or to other piping materials. Provide flanged, socket type molded PVC heavy-duty, 150-pound pattern, drilled in accordance with ANSI B16.5.
3. Socket Welded Joints: Use solvent cement of type recommended by the fitting manufacturer, suitable for service where it is to be used. Joints shall be made by workers skilled in technique of welding PVC pipe.

E. Steel Pipe and Grooved Couplings:

1. Flexible Couplings: Provide flexible grooved couplings for all piping systems routed through subway and U-wall trainway sections.
2. Rigid Couplings: Provide rigid grooved couplings for piping at all other locations as approved by the Engineer.

- F. Diesel Exhaust Pipe: Install as indicated and in accordance with the pipe manufacturer's installation instructions.

3.04 INSTALLATION OF VALVES AND VALVE BOXES

- A. Requirements: Provide valves at points indicated and specified, arranged to give complete and regulating control of piping systems. Provide valves full size of line, unless otherwise indicated. Install valves with neat appearance and grouping, so all parts are easily accessible for operation and maintenance. Install throttling flow valves where indicated, and on each circulating return

branch on domestic hot water systems, on hot water heating systems, and on chilled water systems.

- B. Stop Valves: Install stop valve or a compression stop on water supply lines to each plumbing fixture, including faucets and showers. Where required for accessibility, install them exposed adjacent to faucets. Where fixture trim is specified with integral built-in stops, individual supply stops will not be required. Union end fitting or union shall be installed downstream of stop valve.
- C. Install valves with stems upright or horizontal, not inverted.
- D. Install gate valves for shut-off and isolating service, to isolate equipment, part of system or vertical risers.
- E. Provide drain valve at main shut-off valves and at low points of piping and apparatus.
- F. Air Vent Valves: Manual Air Vent Assemblies: Provide where indicated and at high points to free piping system of air. Connect 1/4 inch copper tubing to top of high point, or other location, and extend down to easily accessible 1/4-inch globe valve, mounted approximately 5 feet above floor, grouped and tagged. Discharge through 1/4 inch copper tubing to nearest floor drain or as approved by the Engineer.
- G. Automatic Type Air Vent Valves: Provide and install as indicated with full sized copper tubing drain line from automatic valve to nearest floor drain or as approved by the Engineer. Pressure Reducing Valves: Install reducing stations along walls or other available spaces with arrangement to permit easy access for servicing and removal of equipment. Provide union of flanged joints to permit springing pipe for valve removal. Provide a three-valve bypass at each pressure-reducing valve.
- H. Chain Operators: Provide chain operators for valves, 4 inches and larger located overhead, 7 feet or more above floor.

3.05 INSTALLATION OF UNIONS, FLANGES, AND GASKETS

- A. Unions: Provide unions where indicated and at each threaded or soldered connection to equipment, tanks, and valves, with the following exceptions:
 - 1. Provide three unions at each three-way automatic valve.
 - 2. Only one union is required at each manually operated threaded valve.
 - 3. In refrigerant piping systems, provide only where indicated.
- B. Locations of Unions: Locate unions so piping can be easily disconnected for removal of equipment, tank, or valve.
- C. Flanges: Provide matching flange faces at each connection to equipment, tanks, and valves. Install gaskets of the required types.

3.06 PAINTING

- A. Except where otherwise indicated, piping systems, ductwork, and HVAC equipment shall not be painted. Where pipes, ductwork, and HVAC equipment are indicated to be painted, such as exposed items in finished rooms, prepare and paint as specified in Section 09 91 00 - Painting. Copper, brass, bronze, and stainless items shall not be painted.

3.07 INSTALLATION OF FLEXIBLE PIPE CONNECTIONS

- A. Align and space piping accurately before installation. Do not use flexible connections to correct misalignment.
- B. Support piping near equipment to prevent weight of pipe from compressing or extending flexible connection from required installed setting.
- C. Install as recommended by the connection manufacturer.
- D. Assemble flexible section with metal retaining rings, built-in braided wire, built-in reinforcement with restriction bolts, or with wire-braid cover. Equip flanged assemblies with limit bolts to restrict maximum travel.
- E. Provide control units for pipe connectors at equipment mounted on vibration isolators, to limit travel.
- F. Provide pipe guides on each side of each expansion joint as recommended by the joint manufacturer.
- G. For expansion joints, provide joints with welded, flanged, or threaded ends, and bases for each joint unless otherwise indicated. Provide single-element joints with bases as an end anchor where indicated. Provide ball joints of stainless steel, malleable iron, ductile iron, carbon steel, bronze, or other alloys suitable for the service intended. Pre-compress expansion joints at time of installation in accordance with manufacturer's installation instructions; and as required by actual temperature of pipe at time of installation.

3.08 INSTALLATION OF GAGES

- A. Requirements: Provide gages or test connections where indicated.
- B. Labels: Install flexible aluminum-faced, black-plastic-backed indicating plate, 3/4-inch by 3 inches, with service engraved into black backing. Labels shall be mounted to gage body with stainless steel rivets.
- C. Gage Cocks: Provide at each gage connection.
- D. Gage Siphon: Install a gage siphon at each hot water gage.

3.09 INSTALLATION OF THERMOMETERS

- A. Location and Type: Install thermometers to be easily read by a person standing on the floor of the room. Use straight, angle, or remote types to suit installation conditions.
- B. Thermometers for Measuring Liquid Temperatures:

1. Install with extension necks or stems to suit insulation on pipes or the lining of tanks.
 2. Install so bulb projects into flow stream and is completely immersed in liquid.
- C. Labels: Install flexible aluminum-faced, black-plastic-backed indicating plate, 3/4-inch by 3 inches, with service engraved into black backing. Labels shall be mounted to gage body with stainless steel rivets.

3.10 INSTALLATION OF ACCESS DOORS AND PANELS

- A. Required Locations: Provide access panels wherever valves, damper operators, fire dampers, gages, and similar items requiring servicing, adjustment, and inspection are concealed. Access panels are not required in furred or suspended ceilings with removable ceiling panels.
- B. Door and Panel Types:
1. In acoustical Tile Ceilings: Provide fill-in type, installed integral with tile pattern. Fill in with ceiling tile.
 2. In Fire-Rated Ceilings: Provide fire-rated access panel, fill-in type or flat-faced, flush mounted panel as required.
 3. Other Locations: Flat-faced flush mounted panel.
 4. Provide plaster frame and grounds for plaster ceilings and walls.
- C. Interface and Coordination: Refer to Section 08 31 00 - Access Doors and Panels, for additional requirements

3.11 INSTALLATION OF PIPE AND VALVE IDENTIFICATION

- A. Provide in accordance with Section 20 40 13 - Identification for Facility Services.

3.12 INSTALLATION OF EQUIPMENT

- A. Place equipment in locations and spaces indicated. Move equipment into spaces through openings as required. Disassemble and reassemble equipment or other work necessary to accomplish this work.
- B. Provide platforms and hangers as required for the installation of equipment.
- C. Mount equipment on vibration isolation units, concrete inertia blocks, or concrete pads as indicated and in accordance with the approved Shop Drawings.
- D. Install, align, and adjust equipment and vibration isolators in accordance with the respective manufacturer's installation instructions and recommendations.
- E. Provide mechanical equipment where indicated with V-belts and cast-iron machined and balanced V-groove sheaves. Key sheaves to shafts and lock with setscrews. On electric motors size NEMA 48 and smaller, fasten sheaves with hardened knurled cup point set screws against flat surface on shaft.

3.13 INSTALLATION OF SEISMIC RESTRAINTS

- A. Provide seismic restraints, bracing, and anchors for piping and equipment in accordance with the requirements of Section 20 30 13 - Vibration Isolation and Seismic Control for Facility Services.

END OF SECTION 20 10 13